



NOTES:

HYDRANTS SHALL BE EQUIPPED WITH ONE 5" STORZ NOZZLE AND TWO 2-1/2" NOZZLES WITH NATIONAL STANDARD THREADS.

CONCRETE BLOCKING SHALL BE POURED SO AS TO LEAVE ALL FITTING BOLTS AND FLANGES EXPOSED.

IF HYDRANT IS LOCATED IN RURAL AREA, HYDRANT SHALL BE LOCATED APPROX. 1' INSIDE R/W.

IF HYDRANT IS LOACTED IN DOT R/W, USE DOT STANDARDS FOR LOCATION OF HYDRANT.

REVISIONS	
DATE	DESCRIPTION
7/08	CORRECTED NOZZLE SIZE & TYPE

TOWN OF KNIGHTDALE
STANDARD DETAILS

STANDARD HYDRANT INSTALLATION - RURAL

STD. NO.

6.01